

20th July 2012

I can confirm the ICYNENE LD-C-50 product passed the breather membrane roof tile underlay drape test for timber pitched roofs. The product must be applied to the underlay in three initial flash coats, leaving each flash coat to cure/set for at least one minute, before the application of the other coat. The first coat is applied 1mm thick, the second coat 2mm thick and the third coat 5mm thick, achieving an approximate combined thickness of 8mm. The product is then applied in the normal manner to the required thickness.

The roof construction comprises of timber rafters, roof tile underlay (breather membrane), single layer of tile/slate battens and tiles. There is no requirement to have counter battens.

Regards,

Mohammed Azad

Project Manager

British Board of Agrément

Bucknalls Lane, Watford, WD25 9BA *

United Kingdom

Tel +44 (0) 1923 665 465

www.bbacerts.co.uk

* If you are visiting the BBA and use a satellite navigation system, use WD25 9NH rather than our standard postcode.

Please consider the environment before printing.